

WRAP METALLIC MARKER TAPE AROUND SERVICE MARKER BOARD. 4 WRAPS MINIMUM. RUN UP BOARD TO SURFACE. MIN 4 WRAPS AT TOP ALSO.

INSTALL BURIED METALLIC MARKER TAPE 3' ABOVE PIPE. TAPE SHOULD READ "CAUTION BURIED SEWER BELOW". CARLTON IND., BLACKBURN MFG. CO. OR EQUAL.

6" SEWER LATERAL SHALL BE THE SAME MATERIAL AS THE MAIN LINE (PVC, EPOXY LINED D.I., C900 OR HDPE)

6" TEE ON SEWER MAIN

SEWER MAIN

FINISHED GRADE

PROPERTY LINE
PERMANENT EASEMENT LINE

2" X 4" BOARD SERVICE MARKER

4' MIN.

6' MINIMUM
VARIES

APPROVED WATERTIGHT PLUG ON CAP WITH "SEWER" IN BLACK PERMANENT MARKER

MINIMUM SLOPE 2% OR 0.02 FT./FT.

45 DEGREES (100%) MAXIMUM SLOPE FOR PVC (2% MINIMUM SLOPE)

CONCRETE POURED IN PLACE FOR SEWER LATERAL OVER 15% SLOPE

NOTES:

1. 2" X 4" BOARD - LENGTH AS REQUIRED IN EVEN FOOT INCREMENTS. PAINT TOP 4' ABOVE GROUND WITH WHITE PAINT. STENCIL IN BLOCK LETTERS THE WORD "SEWER" & TOTAL LENGTH OF THE 2" X 4" BOARD. LETTERING TO BE 3" IN HEIGHT. TOP OF 2" X 4" SHALL BE 4' ABOVE GROUND LEVEL.
2. FOR DUCTILE IRON PIPE IN RIGHT-OF-WAY & EASEMENTS, USE RESTRAINING DEVICE AS SPECIFIED BY THE DISTRICT.
3. PROVIDE DISTANCE IN FEET FROM TEE TO DOWNSTREAM MANHOLE TO THE DISTRICT.

**CROSS VALLEY WATER DISTRICT
STANDARD SEWER DETAILS**

SEWER LATERAL NEW CONSTRUCTION

SD-8

NOT TO SCALE

FEB 2022