



NOTES:

1. MANHOLES SHALL BE WATERTIGHT. GROUT PICK HOLES INSIDE AND OUT WITH NON-SHRINK GROUT.
2. SURFACE RESTORATION IN ACCORDANCE WITH STANDARD SPECIFICATIONS AND LOCAL REGULATORY AUTHORITY.
3. IN NON-PAVED AREAS, INSTALL 6 FT. DIAMETER CONCRETE PAD 6 INCHES THICK AROUND FRAME AND COVER — UNLESS OTHERWISE DIRECTED BY THE DISTRICT.

**CROSS VALLEY WATER DISTRICT
STANDARD SEWER DETAILS**

STANDARD PRECAST MANHOLE

SD-1

NOT TO SCALE

FEB 2022