



NOTES:

1. ALL D.I. JOINTS TO BE RESTRAINED WITH MEGLUG TYPE DEVICES OR APPROVED EQUAL.
2. ALL D.I. PIPE AND FITTINGS TO BE EPOXY LINED.
3. ENTIRE MANHOLE INTERIOR TO BE COATED WITH RAVEN 400 OR EQUAL, UNLESS APPROVED OTHERWISE BY THE DISTRICT.