



NOTES:

1. STAINLESS STEEL TAPPING TEE SHALL BE ROMAC OR SMITH BLAIR ONLY. O.D. RANGES ARE FOR D.I. PIPE.

| | |
|----------------------|-------------|
| O.D. RANGES (INCHES) | |
| 6" | 6.59-6.99 |
| 8" | 8.62-9.06 |
| 12" | 12.90-13.30 |
| 16" | 17.15-17.55 |

 FOR LARGER SIZES, CONSULT THE DISTRICT
2. ALL WATER MAIN TAPS SHALL BE BY AN APPROVED DISTRICT TAPPER DURING SUBMITTALS, UNLESS OTHERWISE SPECIFIED.
3. DEVELOPER/CONTRACTOR SHALL PROVIDE ALL REQUIRED EXCAVATION AND RESTORATION.
4. DEVELOPER/CONTRACTOR TO FURNISH ALL MATERIALS AND BLOCKING AND TEST TAPPING TEE AND VALVE PRIOR TO TAPPING THE MAIN.
5. PRELIMINARY EXCAVATION MAY BE REQUIRED TO VERIFY EXISTING PIPE O.D. AND MATERIAL TYPE.
6. CONNECTIONS NOT ALLOWED ON FRIDAYS, HOLIDAYS, DAY BEFORE HOLIDAYS, OR WEEKENDS.