



CSS1= CATIONIC SLOW SETTING TYPE 1
AR4000W= ASPHALT RUBBER TYPE 4000W
HMA= HOT MIX ASPHALT

NOTES:

1. VALVE BOX SHALL BE ALIGNED AND CLEANED TO ENSURE PROPER VALVE OPERATION.
2. DEFECTIVE OR NON STANDARD VALVE BOX COMPONENTS SHALL BE REPLACED WITH NEW CURRENT DISTRICT STANDARD.
3. PAVEMENT RESTORATION IN ACCORDANCE WITH JURISDICTIONAL AUTHORITY AND DIVISION 7.
4. IF OPERATING NUT IS MORE THAN 3 FEET BELOW GRADE AFTER ADJUSTMENT SEE DETAIL WD-11D.

**CROSS VALLEY WATER DISTRICT
STANDARD WATER DETAILS**

VALVE BOX ADJUSTMENT

WD-11B

NOT TO SCALE

JULY 2023